

## Corrigendum to pre bid replies

Sr. No.	Clause No. / Page No.	RFP Reference	To be read as/New clause
1	Notice inviting bids.  P 8.	ii. Drawings	<p>In Addition to reply to pre bid query no .9 , the same should be read as following</p> <p>The work is in progress and is at advance stage of completion. The As-built CAD drawings would be provided to the Successful Bidder after completion of work.</p> <p>The CAD drawings of layout plans are being provided.</p>
2	RFP Page 46, Clause 7.4	Fire Fighting	<p>In Addition to reply to pre bid query no .25 , the same should be read as following</p> <p>All drawings are being provided. The works being undertaken by the Authority are mentioned in the bidding document. All additional and specific works have to be undertaken by the Concessionaire</p>
3	General	FINANCIAL ASPECT	<p>In Addition to reply to pre bid query no .31 , the same should be read as following</p> <p>As per Bid Document.</p> <p>Hypothecation of movable assets is not allowed, unless approved by the authority. Please refer to Draft Concession agreement clause 3.2.b</p>
4	Clause 7.4 (page 46)	Scope of Work	<p>In Addition to reply to pre bid query no .37 , the same should be read as following</p> <p>Minor chiselling and puncturing may be allowed for concealed services subject to the conditions that:</p> <ol style="list-style-type: none"> <li>1. No damage to Heritage Structure shall be</li> </ol>

			<p>allowed.</p> <p>The chiselled / punctured area should be restored to original condition by the Concessionaire at its own cost and expense</p>
5	Appendix X (page 97)	Qila Mubarak, Patiala	<p>In Addition to reply to pre bid query no .51 , the same should be read as following</p> <p>No common connection is available for power. Concessionaire will have to take his own connection. Source of water is from Municipal Corporation. Capacity of water tanks is 1lakh litres for fire fighting and 67,000 litres for drinking water.</p>
6		Others	<p>In Addition to reply to pre bid query no .63 , the same should be read as following</p> <p>To be decided by the Concessionaire himself in Concessionaire's area.</p>
7		Serial No. of queries from no 21 to no 70	Serial No. of queries from no 21 to no. 70 should be considered as no. 16 to no. 65